

Emission Test Certificate

Wednesday 9th August 2023

Supplier The Flooring Lab (35 Naxos Way, Keysborough, VIC, 3173, Australia).
Product Name The Flooring Lab 14mm Engineered Timber Flooring
Date Tested August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

Specification	14mm Engineered Timber Flooring
Green Building Council of Australia Green Star – Design & As Built V1.3-13.2 Green Star Interiors V1.3-12.2	
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.135 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.008 \text{ mg/m}^2/\text{hr}$

Dr. Vyt Garnys
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Dr Tuan Duong
Ph.D., B.Eng. (Chemical)
Senior Consultant

Issued Date: 9/8/2023

Expired Date: 9/8/2028

P23070021