

# Emission Test Certificate

Wednesday 9<sup>th</sup> August 2023

**Supplier** The Flooring Lab (35 Naxos Way, Keysborough, VIC, 3173, Australia).  
**Product Name** The Flooring Lab 9mm Hybrid Flooring  
**Date Tested** August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)  
**Test Method** ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Emission Data (24 hours)

Specification	
<b>Green Building Council of Australia Green Star – Design &amp; As Built V1.3-13.2 Green Star Interiors V1.3-12.2</b>	<b>9mm Hybrid Flooring</b>
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.035 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.006 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys  
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr Tuan Duong  
Ph.D., B.Eng. (Chemical)  
Senior Consultant

Issued Date: 9/8/2023

Expired Date: 9/8/2028

P23070021