

# Emission Test Certificate

Tuesday 9<sup>th</sup> September 2025

Manufacturer	The Flooring Lab (35 Naxos Way, Keysborough, VIC 3173, Australia).
Product Name	Artureon 8mm Laminate Flooring
Date Tested	7 <sup>th</sup> August 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method	ASTM D5116:2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

**Emission Data (24 hrs):**

<b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.2</b>	<b>Artureon</b> <b>8mm Laminate Flooring</b>
Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate Limit: ≤0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound (C <sub>6</sub> -C <sub>16</sub> ) Emission Rate: 0.014 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: 0.013 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr. Tuan Duong  
PhD, B.Eng. (Chemical)  
Senior Consultant